

TECHNICAL DOCUMENT #002

LOCAL LIMITS SUMMARY

Pollutant	Current Local Limit
	(mg/l)
Arsenic	0.180
Cadmium	0.050
Chromium	2.200
Hex. Chrom.	0.590
Copper	BMP**
Cyanide	0.046
Iron	NONE
Lead	0.650
Mercury	BMP**
Molybdenum	0.160
Nickel	0.430
Selenium	0.074
Silver	NONE
Total Dissolved Solids	7750
Zinc	1.730
Toluene	75.0

** Best Management Practices Plan

EFFECTIVE DATE: JULY 9, 2013